

Storage Tanks for Storing Liquid Public Dangerous Goods of a Certain Scale Shall Conduct Regular Inspection to Keep Safe



Key Points for Regular Inspection

■ What Tanks Need to Be Inspected?

Outdoor tanks that store liquid public hazardous goods with a capacity of 10,000 cubic meters or more.

■ What and When to be Inspected

- (1) External Inspection: The first inspection shall be conducted after 5 years the tank starts operation, with subsequent inspection every 2 years thereafter.
- (2) Internal Inspection: The first inspection shall be conducted after 10 years the tank starts operation, with subsequent inspection every 5 years thereafter. The inspection period may be extended once if approved by a professional organization.
- (3) Tanks installed before April 10, 2024 must complete their first inspection before April 9, 2029.



內政部消防署

National Fire Agency,
Ministry of the Interior, R.O.C.

廣告